



St. Stogovo 13 A 1000 Skopje, Macedonia
Phone: 389 2 3124 322 Fax: 3126 920 E: mail@euromakkontrol.com



EUROMAK-KONTROL INSPECTION DEPARTMENT QUALITY SUPERINTENDENCE CORPORATION

QUALITY CERTIFICATE No. 28-3/21

Skopje, 29.06.2021

I. GENERAL INFORMATION

1. **Product name:** Nilego ANTI-SLIP Waterproofing non-slip final waterproofing
2. **Manufacturer:** SK-MONT DOOEL, export-import, Kumanovo
3. **Date and place of inspection:** 01.06.-25.06.2021 год., Laboratory of Euromak Kontrol - Skopje (Report No.XIV-06-21/78)
4. **Conditions of inspection:** Sample submitted
5. **Conditions during inspection:** The Law on Chemicals ("Official Gazette of the Republic of Macedonia" No. 145/10), The regulation on the conditions regarding the health correctness of items for general use that can be put on the market ("Official Gazette of SFRY" No. 26/83 и 50/89), The Rulebook on the criteria for microbiological and chemical purity of cosmetic products and the methods for checking those criteria ("Official Gazette of the Republic of Macedonia" No. 94/2010) and The Law on Product Safety ("Official Gazette of the Republic of Macedonia" No. 33/06, 63/07, 24/11, 51/11, 148/11, 164/13, 152/15).

II. SUBJECT OF INSPECTION

1. **Qualitative inspection:** Organoleptic, physical-chemical analysis of Nilego ANTI SLIP Waterproofing non-slip final waterproofing.

III. INSPECTION REPORT

Organoleptic analysis	Results
Appearance	Thick mass
Color	Gray
Odor	Characteristic of the product
Packing	Plastic packaging of 1 kg

3.1 Physical and chemical analysis

Parameters	Declared values	Results
Solubility in water	/	Total
pH (5% solution)	max.12,5	11,50
Total dry residue at 105°C	/	87,80 %
Volatile components 105°C	/	12,20 %
Specific gravity g/cm ³	/	1,18 g/cm ³

3.2 Manufacturer Specification:

Polymers
Fillers
Pigments
Plasticizers
Homogenizer
Stabilizers
UV stabilizers

IV. USE OF THE PRODUCT

Nilego ANTI-SLIP Waterproofing one-component final waterproofing - excellent abrasion and adhesion, prevents slipping, water and frost resistance. Used to protect slippery surfaces around swimming pools, underground and above-ground parking lots, terraces, slippery interior and exterior surfaces, access ramps, parking lots, etc. Concrete should be at least 28 days old. The moisture content of the substrate must be less than 10%.

V. DOSAGE AND METHOD OF USE

It is applied on concrete, stone, plaster, tiles, terrazzo, marble, etc. It is applied directly on new or old concrete. The surface must be thoroughly clean, dust-free, degreased and dry. It is applied at temperatures from 5°C to 30°C. Drying time at room temperature 3-4 hours.

Each subsequent layer is applied after 5-6 hours at a temperature of 25°C

Do not dilute with any type of thinner or water.

Before use, mix with a mixer at low speed.

Store at room temperature, away from heat sources and sunlight. Consumption 1.2-1.5 kg/m² depending on the roughness of the surface.

VI. SAFETY MEASURES

6.1 Health hazard

The product is harmful if it comes into contact with the eyes. It may cause eye damage. Keep out of the reach of children. Do not mix with other chemicals. In case of contact with eyes, rinse immediately with plenty of water and seek medical advice (show the label where possible). Wear protective gloves, protective clothing and safety glasses when using.

VII. CONCLUSION

Based on the performed physico-chemical characteristics and the obtained results, it is concluded that the sample in question, **Nilego ANTI-SLIP Waterproofing**, meets the requirements in accordance with the Law on Chemicals ("Official Gazette of the Republic of Macedonia" No. 145/10), the Rulebook on the conditions regarding the health safety of objects for general use (Official Gazette of the Republic of Macedonia 26/83 and 50/89), and the Law on Product Safety (Official Gazette of the Republic of Macedonia No. 33/06, 63/07, 24/11, 51/11, 148/11, 164/13, 152/15) and can be put into use.

Inspector – Jelena Trajkovikj

creates

Senior Inspector – Suzana Temelkoska

controls

Technical manager – Suzana Temelkoska

approves



NOTE: The inspection certificate refers exclusively to the conditions and place at the time the inspection was performed. Reproduction of this Inspection Report is not permitted, only with the approval of the inspection sponsor and the inspection body.

This inspection has been carried out to the best of our knowledge and conscience and this certificate does not absolve the seller and the buyer from their contractual responsibilities. In case of quality superintendence or inspection of goods we are responsible in accordance with the deed contract, in case of taking over of goods in accordance with principles of power of attorney, while for weight and quality quarantine transactions we are responsible in accordance with the stipulations of contracts concluded relative to such transactions